

SECTION 26 22 00 {16461}  
LOW-VOLTAGE TRANSFORMERS  
{ DRY TYPE TRANSFORMERS }

\*\*\*\*\*

This section includes enclosed dry type transformers for lighting and power loads, with primaries and secondaries rated 600 volts and less. Dry type transformers rated for nonlinear loads are covered in another Section.

Manufacturers listed in this section were identified as representative and not as an endorsement for meeting this specification. For additional product information, visit 4Specs at [www.4specs.com](http://www.4specs.com), ARCAT at [www.arcata.com](http://www.arcata.com), First Source at [www.reedfirstsource.com](http://www.reedfirstsource.com), SpecSource at [www.specsource.com](http://www.specsource.com), and Sweets Network at [products.construction.com](http://products.construction.com).

This section includes performance, proprietary, and descriptive type specifications. Edit to avoid conflicting requirements.

Contact the CSRF Support Center at [supportcenter@csrf.org](mailto:supportcenter@csrf.org) to submit comments or suggestions for improvements to this specification. Visit the SPECTEXT web site at [www.spectext.com](http://www.spectext.com) for current product announcements.

\*\*\*\*\*

## PART 1 GENERAL

### 1.1 SUMMARY

- A. Section includes two-winding transformers; shielded transformers; autotransformers; and buck-and-boost transformers.
- B. Related Sections:
  - 1. Section 26 05 33 - Raceway and Boxes for Electrical Systems.
  - 2. Section 26 22 03 - Low-Voltage Transformers For Nonlinear Loads.
  - 3. Section 26 22 06 - Low-Voltage Transformer Load Centers.
- C. Related Sections:
  - 1. Section 16128 - Raceway and Boxes for Electrical Systems.
  - 2. Section 16462 - Transformers for Nonlinear Loads.
  - 3. Section 16463 - Transformer Load Centers.

### 1.2 REFERENCES

\*\*\*\*\*

List reference standards included within text of this section. Edit the following for Project conditions.

\*\*\*\*\*

- A. National Electrical Manufacturers Association:

1. NEMA ST 1 - Specialty Transformers (Except General Purpose Type).
2. NEMA ST 20 - Dry Type Transformers for General Applications.

B. International Electrical Testing Association:

1. NETA ATS - Acceptance Testing Specifications for Electrical Power Distribution Equipment and Systems.

### 1.3 SUBMITTALS

\*\*\*\*\*

Only request submittals needed to verify compliance with Project requirements.

\*\*\*\*\*

- A. Section 01 33 00 - Submittal Procedures {01330 - Submittal Procedures}: Submittal procedures.
- B. Product Data: Submit outline and support point dimensions of enclosures and accessories, unit weight, voltage, kVA, and impedance ratings and characteristics, tap configurations, insulation system type, and rated temperature rise.
- C. Test Reports: Indicate loss data, efficiency at 25, 50, 75 and 100 percent rated load, and sound level.

### 1.4 CLOSEOUT SUBMITTALS

- A. Section 01 70 00 - Execution and Closeout Requirements {01700 - Execution Requirements}: Closeout procedures.
- B. Project Record Documents: Record actual locations of transformers.

### 1.5 QUALIFICATIONS

- A. Manufacturer: Company specializing in manufacturing products specified in this section with minimum three years [documented] experience.

### 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Section 01 60 00 - Product Requirements {01600 - Product Requirements}: Product storage and handling requirements.
- B. Store in clean, dry space. Maintain factory wrapping or provide additional canvas or plastic cover to protect units from dirt, water, construction debris, and traffic.
- C. Handle in accordance with manufacturer's written instructions. Lift only with lugs provided. Handle carefully to avoid damage to transformer internal components, enclosure, and finish.