

SECTION 26 28 19 {16411}

ENCLOSED SWITCHES

{ENCLOSED SWITCHES}

This section includes enclosed switches for use as disconnects in service and distribution systems rated 600 volts and less.

Manufacturers listed in this section were identified as representative and not as an endorsement for meeting this specification. For additional product information, visit 4Specs at www.4specs.com, ARCAT at www.arcata.com, First Source at www.reedfirstsource.com, SpecSource at www.specsource.com, and Sweets Network at products.construction.com.

This section includes performance, proprietary, and descriptive type specifications. Edit to avoid conflicting requirements.

Contact the CSRF Support Center at supportcenter@csrf.org to submit comments or suggestions for improvements to this specification. Visit the SPECTEXT web site at www.spectext.com for current product announcements.

PART 1 GENERAL

1.1 SUMMARY

- A. Section includes fusible and nonfusible switches.
- B. Related Sections:
 - 1. Section 26 28 13 - Fuses.
- C. Related Sections:
 - 1. Section 16491 - Fuses.

1.2 REFERENCES

List reference standards included within text of this section. Edit the following for Project conditions.

- A. National Electrical Manufacturers Association:
 - 1. NEMA FU 1 - Low Voltage Cartridge Fuses.
 - 2. NEMA KS 1 - Enclosed and Miscellaneous Distribution Equipment Switches (600 Volts Maximum).
- B. International Electrical Testing Association:

1. NETA ATS - Acceptance Testing Specifications for Electrical Power Distribution Equipment and Systems.

1.3 SUBMITTALS

Only request submittals needed to verify compliance with Project requirements.

- A. Section 01 33 00 - Submittal Procedures {01330 - Submittal Procedures}: Submittal procedures.
- B. Product Data: Submit switch ratings and enclosure dimensions.

1.4 CLOSEOUT SUBMITTALS

- A. Section 01 70 00 - Execution and Closeout Requirements {01700 - Execution Requirements}: Closeout procedures.
- B. Project Record Documents: Record actual locations of enclosed switches and ratings of installed fuses.

1.5 QUALIFICATIONS

- A. Manufacturer: Company specializing in manufacturing products specified in this section with minimum three years [documented] experience.