

SECTION 28 05 29 {16072}

HANGERS AND SUPPORTS FOR ELECTRONIC SAFETY AND SECURITY

{HANGERS AND SUPPORTS FOR ELECTRONIC SAFETY AND SECURITY}

This section includes basic materials and methods for fastening and supporting safety and security products and equipment. Also included is firestopping of safety and security work.

Manufacturers listed in this section were identified as representative and not as an endorsement for meeting this specification. For additional product information, visit 4Specs at www.4specs.com, ARCAT at www.arcats.com, First Source at www.reedfirstsource.com, SpecSource at www.specsource.com, and Sweets Network at products.construction.com.

This section includes performance, proprietary, and descriptive type specifications. Edit to avoid conflicting requirements.

Contact the CSRF Support Center at supportcenter@csrf.org to submit comments or suggestions for improvements to this specification. Visit the SPECTEXT web site at www.spectext.com for current product announcements.

PART 1 GENERAL

1.1 SUMMARY

A. Section Includes:

1. Conduit supports.
2. Formed steel channel.
3. Spring steel clips.
4. Sleeves.
5. Mechanical sleeve seals.
6. Firestopping relating to electrical work.
7. Firestopping accessories.
8. Equipment bases and supports.

B. Related Sections:

1. Section 03 30 00 - Cast-In-Place Concrete: Product requirements for concrete for placement by this section.
2. Section 26 05 29 - Hangers and Supports for Electrical Systems.
3. Section 27 05 29 - Hangers and Supports for Communications Systems.

C. Related Sections:

1. Section 03300 - Cast-In-Place Concrete: Product requirements for concrete for placement by this section.
2. Section 16070 - Hangers and Supports for Electrical Systems.
3. Section 16071 - Hangers and Supports for Communications Systems.

1.2 REFERENCES

List reference standards included within text of this section. Edit the following for Project conditions.

- A. ASTM International:
 - 1. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
 - 2. ASTM E119 - Standard Test Methods for Fire Tests of Building Construction and Materials.
 - 3. ASTM E814 - Standard Test Method for Fire Tests of Through-Penetration Fire Stops.
 - 4. ASTM E1966 - Standard Test Method for Fire-Resistive Joint Systems.
- B. FM Global:
 - 1. FM - Approval Guide, A Guide to Equipment, Materials & Services Approved By Factory Mutual Research For Property Conservation.
- C. National Fire Protection Association:
 - 1. NFPA 70 - National Electrical Code.
- D. Underwriters Laboratories Inc.:
 - 1. UL 263 - Fire Tests of Building Construction and Materials.
 - 2. UL 723 - Tests for Surface Burning Characteristics of Building Materials.
 - 3. UL 1479 - Fire Tests of Through-Penetration Firestops.
 - 4. UL 2079 - Tests for Fire Resistance of Building Joint Systems.
 - 5. UL - Fire Resistance Directory.
- E. Intertek Testing Services (Warnock Hersey Listed):
 - 1. WH - Certification Listings.

1.3 DEFINITIONS

- A. Firestopping (Through-Penetration Protection System): Sealing or stuffing material or assembly placed in spaces between and penetrations through building materials to arrest movement of fire, smoke, heat, and hot gases through fire rated construction.

1.4 SYSTEM DESCRIPTION

Use this article carefully; restrict statements to describe components used to assemble system. Do not repeat statements made in SUMMARY Article; "Section includes" paragraph.

Select the following primary performance criteria specifically required for Project. Edit subject text to suit particular material being utilized.

- A. Firestopping Materials: [ASTM E119] [ASTM E814] [UL 263] [UL 1479] to achieve fire ratings as noted on Drawings for adjacent construction, but not less than 1 hour fire rating.